
From: Jeffrey C Heffelman (Generation - 3) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=JEFFRE3]
Sent: 2/25/2015 8:54:59 AM
To: Ed Baine (Generation - 3) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Edwar62]
Subject: FW: Ash Pond ABC inspection 02/23/15
Attachments: 20150224171611779.pdf

fyi

From: Jeffrey R Marcell (Generation - 3)
Sent: Tuesday, February 24, 2015 5:16 PM
To: Michael J Winters (Generation - 34)
Cc: John Cima (Generation - 34); Jeffrey C Heffelman (Generation - 3); Kenneth Roller (Services - 6)
Subject: RE: Ash Pond ABC inspection 02/23/15

Attached.

No discharge at C Pond. No standing water.

Note: No seeping or dripping observed.

Area covered in snow; Approximately 4"-5" during recent event.

Let me know if you have any questions.

Jeff Marcell

Environmental Supervisor

Possum Point Power Station

Ladysmith & Remington CT Sites

703-441-3813 (phone)

8-795-3813 (tie)

703-441-3897 (fax)